



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.

NABL Accredited Laboratory Bangalore urban

TEST REPORT

Address of the sampling location :- GEETANJALI INTERNATIONAL SCHOOL Sy No. 80/2, Mandur, New Airport Road, Budhigere Road Bangalore-560049				Report date: 01/09/2026	
				Report Number: 0019	
				Reference: TRF	
				Sample code: 0019	
				Date of Sample collection: 29/08/2026	
				Analysis start date: 29/08/2026	
				Analysis completion date: 31/08/2026	
				Sample quantity: 1 Liter	
Sample Particulars: R.O water					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.2	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu S/cm$ @25°C Temp	420	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.1	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	260	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as $CaCO_3$, mg/l	50.0	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as $CaCO_3$, mg/l	140.0	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	35.3	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	12.6	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	40.0	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	26.4	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	8.4	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	0.1	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S. Senior Analyst/Junior Analyst				Authorized Signatory: Pavithra B.S Technical Manager: Pavithra B.S	

RDWSD/WQMSP/TeR/01

Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---

Page 1 of 1

Manager
Geetanjali International School
 Sy. No. 80/2, Mandur, New Airport
 Budigere Road, Bengaluru - 560049.

Principal
Geetanjali International School
 Sy. No. 80/2, Mandur, New Airport
 Budigere Road, Bengaluru - 560049.